



ASZH66L 480-505M

HALF-CELL Double Glass Monocrystalline PERC PV Module

480-505W

21.27%

0.45%

POWER RANGE

MAXIMUM EFFICIENCY

YEARLY DEGRADATION





30 YEARS OUTPUT GUARANTEE











IEC 61215/IEC 61730/IEC 61701/IEC 62716/UL6 1730

ISO 14001: Environmental Management System

ISO 9001: Quality Management System

ISO45001: Occupational Health and Safety Management System

*As there are different certification requirements in different markets please contact your local znshine sales representative for the specific certificates applicable to the products in the region in which the products are to be used

KEY FEATURES-



Excellent Cells Efficiency

MBB technology reduce the distance between busbars and finger grid line which is benefit to power increase.



Better Weak Illumination Response

More power output in weak light condition, such as haze, cloudy, and early morning.



Anti PID

Ensured PID resistance through the quality control of cell manufacturing process and raw materials.



Adapt To Harsh Outdoor Environment

Resistant to harsh environments such as salt, ammonia, sand, high temperature and high humidity environment.



TIER 1

Global, Tier 1 bankable brand, with independently certified advanced automated manufacturing.



Excellent Quality Managerment System

Warranted reliability and stringent quality assurances well beyond certified requirements.

Front View

*Remark: customized frame color and cable length available upon request

*NMOT:Irradiance800W/m²,AmbientTemperature20°C,AM1.5,WindSpeed1m/s



DIMENSIONS OF PV MODULE(mm) I-V CURVES OF PV MODULE(490W) Barcode 1 Cells temp. = 25 °C Incident Irrad. = 1000 W/m² Drainage holes Incident Irrad = 800 W/m² Current [A] Incident Irrad. = 600 W/m² Mounting holes Incident Irrad. = 400 W/m² Incident Irrad. = 200 W/m² Mounting holes COD. 20 Voltage [V] Junction box/ P-V CURVES OF PV MODULE(490W) Grounding identification Grounding holes Power [W]

Back View

ELECTRICAL CHARACTERISTICS | STC* MECHANICAL DATA 480 485 490 495 500 505 Solar cells Mono PERC Nominal Power Watt Pmax(W)* Power Output Tolerance Pmax(%) 0~+3 0~+3 0~+3 0~+3 0~+3 0~+3 Cells orientation 132 (6×22) Maximum Power Voltage Vmp(V) Module dimension 2094×1134×35 mm (With Frame) 38.30 37.30 37.50 37.70 37.90 38.10 Maximum Power Current Imp(A) Weight 29.5 ±1.0 kg 12.87 12.94 13.00 13.07 13.13 13.19 Open Circuit Voltage Voc(V) 44.80 45.00 45.20 45.40 45.60 45.80 Glass 2.0 mm+2.0mm, High Transmission, AR Coated Heat Strengthened Glass Short Circuit Current Isc(A) IP 68, 3 diodes Junction box 13.61 13.67 13.73 13.79 13.85 Module Efficiency (%) 4 mm² ,350 mm (With Connectors) 20.21 20.42 20.64 20.85 21.06 *The data above is for reference only and the actual data is in accordance with the pratical testing Connectors * MC4-compatible *STC (Standard Test Condition): Irradiance 1000W/m², Module Temperature 25°C, AM 1.5 *Measuring tolerance: ±3% *Please refer to regional datasheet for specified connector **WORKING CONDITIONS ELECTRICAL CHARACTERISTICS | NMOT TEMPERATURE RATINGS*** Maximum Power Pmax(Wp) 44°C ±2°C Maximum system voltage 1500 V DC 358.80 362.60 366.10 369.90 373.50 377.10 Maximum Power Voltage Vmpp(V) Temperature coefficient of Pmax -0.35%/℃ Operating temperature -40°C~+85°C 34.70 34.90 35.10 35.30 35.50 35.70 Maximum Power Current Impp(A) Temperature coefficient of Voc -0.29%/℃ Maximum series fuse 10.35 10.39 10.44 10.49 10.53 10.57 Open Circuit Voltage Voc(V) 0.05%/°C Front Side Maximum Static Loading Up to 5400 Pa Temperature coefficient of Isc 42.80 41.90 42.00 42.20 42.40 42.60 Rear Side Maximum Static Loading Up to 2400 Pa Short Circuit Current Isc(A) 10.99 11.04 11.09 *Do not connect Fuse in Combiner Box with two or more strings in parallel connection

**Customized packaging is available upon request.

Theyonlyserveforcomparisonamongdifferentmoduletypes

Remark: Electrical data in this catalog do not refer to a single module and the vare not part of the offer.

and please carefully read the safety and installation instructions before using our PV modules.

Voltage [V]

 $Caution: Please \ be \ kindly \ advised \ that \ PV \ modules \ should \ be \ handled \ and \ installed \ by \ qualified \ people \ who \ have \ professional \ skills$